OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0569:121 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Gentex, 10985 Chicago Dr., Zeeland MI 49464

Contact: *Keiffer Sestric (616) 392-7195 Fax (616) 392-4219

DESIGN: Models ZMS4 and AVS44 sync control modules. Refer to listee's data sheet for additional

detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and

in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as sync control module for use with listee's separately listed compatible strobe lights.

For indoor use only.





This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: DECEMBER 9, 2003 Listing Expires June 30, 2004

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager